

**BEFORE THE
PUBLIC SERVICE COMMISSION OF ARKANSAS**

**In the Matter of Southwestern Electric)
Power Company's Petition for a)
Declaratory Order Finding that)
Installation of Environmental Controls)
at the Flint Creek Power Plant Is in the)
Public Interest)**

Docket No. 12-008-U

**DIRECT TESTIMONY OF
PAUL CHERNICK
ON BEHALF OF
THE SIERRA CLUB**

Resource Insight, Inc.

JUNE 29, 2012

TABLE OF CONTENTS

I.	Identification and Qualifications	1
II.	Introduction.....	2
III.	The Northwest Arkansas Load Pocket	12
IV.	Overstatement of Gas Prices.....	22
V.	Alternative Resource Options.....	29
	A. Energy Efficiency	29
	B. Purchase of Natural-Gas Combined-Cycle Capacity	32
	C. Other Promising Generation Construction Options	38
VI.	Estimates of Control Costs	40

TABLE OF EXHIBITS

Exhibit PLC-1	<i>Professional Qualifications of Paul Chernick</i>
Exhibit PLC-2	<i>Green Energy Economics Group, Electric Energy Efficiency Resource Acquisition Options for Nevada Power Company, December 20, 2011</i>

1 **I. Identification and Qualifications**

2 **Q: Mr. Chernick, please state your name, occupation and business address.**

3 A: I am Paul L. Chernick. I am president of Resource Insight, Inc., 5 Water
4 Street, Arlington, Massachusetts.

5 **Q: Summarize your professional education and experience.**

6 A: I received an SB degree from the Massachusetts Institute of Technology in June
7 1974 from the Civil Engineering Department, and an SM degree from the
8 Massachusetts Institute of Technology in February 1978 in technology and
9 policy. I have been elected to membership in the civil engineering honorary
10 society Chi Epsilon, and the engineering honor society Tau Beta Pi, and to
11 associate membership in the research honorary society Sigma Xi.

12 I was a utility analyst for the Massachusetts Attorney General for more
13 than three years, and was involved in numerous aspects of utility rate design,
14 costing, load forecasting, and the evaluation of power supply options. Since
15 1981, I have been a consultant in utility regulation and planning, first as a
16 research associate at Analysis and Inference, after 1986 as president of PLC, Inc.,
17 and in my current position at Resource Insight. In these capacities, I have
18 advised a variety of clients on utility matters.

19 My work has considered, among other things, the cost-effectiveness of
20 prospective new generation plants and transmission lines, retrospective review
21 of generation-planning decisions, ratemaking for plant under construction, rate-
22 making for excess and/or uneconomical plant entering service, conservation
23 program design, cost recovery for utility efficiency programs, the valuation of
24 environmental externalities from energy production and use, allocation of costs
25 of service between rate classes and jurisdictions, design of retail and wholesale

1 rates, and performance-based ratemaking and cost recovery in restructured gas
2 and electric industries. My professional qualifications are further summarized in
3 Exhibit PLC-1.

4 **Q: Have you testified previously in utility proceedings?**

5 A: Yes. I have testified more than 250 times on utility issues before various regula-
6 tory, legislative, and judicial bodies, including the utility regulators of thirty
7 states, five Canadian provinces, New Orleans, the District of Columbia, Austin
8 Texas, and two U.S. federal agencies.

9 **Q: Have you testified previously before this Commission?**

10 A: Yes. I testified on lost-revenue recovery and shareholder incentives in Energy
11 Arkansas's 2009 rate proceeding, Docket No. 09-084-U; on fuel switching,
12 program administration and oversight, and programs for large customers in the
13 Energy Efficiency Notice of Inquiry proceeding, Docket No. 10-010-U; on lost
14 contributions to fixed costs, avoided costs, and shareholder incentives for
15 program performance in the Innovative Ratemaking proceeding, Docket No. 08-
16 137-U; and on opt-out and self-direct programs for industrial energy efficiency
17 in Docket No. 10-101-R.

18 **Q: Please summarize your experience in planning of utility resources.**

19 A: I have testified on need, economics and other issues for utility power supply in
20 scores of proceedings since 1978, as well as several proceedings regarding the
21 need for transmission facilities.

22 **II. Introduction**

23 **Q: On whose behalf are you testifying?**

24 A: My testimony is sponsored by the Sierra Club.

1 **Q: Please provide a brief summary of this proceeding and your conclusions.**

2 A: In this proceeding, the Southwestern Electric Power Company (SWEPCo or the
3 Company) requests that the Public Service Commission find that the installation
4 of some very expensive environmental controls (the Project) at Flint Creek
5 would be in the public interest. That finding would provide SWEPCo with some
6 assurance of cost recovery, which the Company suggests is necessary for it to
7 proceed with the Project, rather than retire or repower the coal plant.

8 In order for the Commission to know whether the Project is in the public
9 interest, SWEPCo must derive a realistic estimate of Project costs and compare
10 those costs to the costs of the most attractive alternatives under realistic
11 conditions. The Company has failed to meet any of those standards: it has not
12 provided serious site-specific estimates of the control costs, has ignored the
13 most attractive alternatives (particularly enhanced energy-efficiency programs
14 and the purchase of an existing efficient combined-cycle plant), and used
15 unrealistic cost inputs (including gas prices, SWEPCo's share of transmission
16 costs, and even the need for transmission upgrades).

17 Hence, the Company has not met its burden and the Commission should
18 not endorse the Project.

19 **Q: What is the scope of your testimony?**

20 A: I review the adequacy of the analysis of the economics of major environmental
21 retrofits of the 518-MW Flint Creek coal-fired power plant by its lead owner, the
22 Southwestern Electric Power Company (SWEPCo or the Company) and its
23 partner, the Arkansas Electric Cooperative Corporation (AECC). I examine the
24 reliability of SWEPCo's estimates of the costs of continued operation of the coal
25 plant, the costs related to transmission constraints, and alternatives to the coal
26 plant not considered by SWEPCo.

1 In my review, I have concentrated on the analysis offered by SWEPCo,
2 specifically through the direct testimony of Company Witness Scott Weaver.
3 The Company also sponsors a similar parallel analysis by Judah Rose of ICF
4 International, based on similar assumptions. I sometimes refer to the Rose direct
5 testimony and discovery responses, where they describe SWEPCo's assumptions
6 most clearly. My testimony also touches on the direct testimonies of Company
7 Witnesses John Hendricks on environmental requirements, Paul Hassink on
8 transmission issues, and Christian Beam on the environmental controls. My
9 references to discovery responses (in the form "party Data Request set-number,"
10 sometimes specifying attachments) are SWEPCo's responses, except where I
11 specifically cite to AECC responses.

12 **Q: What is SWEPCo requesting in this proceeding?**

13 A: The Company has petitioned the Arkansas Public Service Commission (APSC or
14 the Commission) for a declaratory order finding that it would be in the public
15 interest to install environmental controls at the Flint Creek power plant near
16 Gentry, Arkansas. The Company and AECC each own a 50% share of Flint Creek
17 and jointly seek to invest \$504 million, including allowance for funds used
18 during construction (AFUDC), to construct, own, and operate the following
19 improvements, to which I will refer to collectively as the Project:

- 20 • a dry flue-gas-desulfurization system (DFGD or dry scrubber) to reduce the
21 plant's emissions of sulfur dioxide (SO₂);
- 22 • an activated-carbon-injection system to reduce the plant's emissions of
23 mercury;
- 24 • low-NO_x burners and overfire air to reduce the plant's emissions of oxides
25 of nitrogen;

- 1 • a pulse-jet fabric filter (or baghouse) integrated into the scrubber, to capture
2 fine particulates and associated hazardous air pollutants (including the
3 mercury adsorbed onto the activated carbon particles;
- 4 • support equipment for the delivery of lime (the chemical reagent used to
5 remove SO₂ in the scrubber) and activated carbon, and the disposal of the
6 scrubber and baghouse wastes;
- 7 • various investments associated with the environmental retrofits or general
8 life extension and upgrades, including landfill development work, installa-
9 tion of continuous emission monitoring systems, and improvements to unit
10 controls, steam coils, the balanced-draft system, and materials handling
11 (Petition for Declaratory Order at 7–8).

12 In addition to the components of the Project, and the normal expenses and
13 investments associated with operating a coal plant, SWEPCo anticipates that
14 continued operation of Flint Creek will require investments for management of
15 coal-combustion-waste materials and for additional NO_x control. The Company
16 included estimates of these costs in its economic analyses.

17 **Q: Why is SWEPCo proposing the Project?**

18 A: The Company states that these improvements in air-pollution controls and other
19 systems for Flint Creek are required to meet more stringent emissions limits in
20 order to comply with the Mercury and Air Toxics Standards (MATS) and the
21 Regional Haze Rule. The MATS requirements would take effect in 2016, and
22 would require the baghouse and injection of activated carbon.

23 The timing and stringency of the Regional Haze Rule are somewhat
24 uncertain, but the U.S. EPA is committed to ensuring compliance with the best-
25 available retrofit-technology (BART) requirements of the Rule by 2018. These
26 will likely require some form of flue-gas desulfurization, as well as reductions

1 in NOx emissions. The low-NOx burners and overfire air would reduce NOx
2 emissions but may not be sufficient, depending on the final BART requirements
3 of that rule (Petition at 5–7; Hendricks Direct at 5, 11, 15–16).

4 **Q: Please describe the Company’s analysis.**

5 A: In Mr. Weaver’s testimony, SWEPCo presented results for the following four
6 options:

- 7 • Investing \$721 million (\$361 million for SWEPCo’s share), in environ-
8 mental retrofits at Flint Creek and continuing to run the unit on coal.¹ The
9 Company’s share of the environmental retrofits would include \$252
10 million for a scrubber, a baghouse, and carbon injection in 2016, to control
11 sulfur, particulate, and mercury emissions, respectively; \$72 million for
12 selective catalytic reduction for NOx control in 2020 in the base case (with
13 sensitivities for installations in 2016 and never); and \$37 million for
14 control of coal combustion residuals by 2017. This is Option 1.
- 15 • Converting Flint Creek to burn natural gas at a cost of \$110 million for
16 SWEPCo’s share. The Company assumes that the natural-gas plant, which
17 might be economically dispatched at a 10–20% capacity factor, would be
18 forced to run at 70% of full capacity every hour in several months (or
19 about 40% on an annual basis) to back up the transmission system in the
20 northwest Arkansas (NW-AR) region. This is Option 2.
- 21 • The Company’s Option 3 is retiring Flint Creek and building a new 608-
22 MW combined-cycle plant, plus 116 MW of peaking duct-firing capacity

¹For simplicity, I cite SWEPCo’s share of the costs in my discussion below, except as noted. Mr. Weaver’s Table 6 shows SWEPCo’s estimate of its share of the costs, and his workpapers show the AFUDC.

1 (of which SWEPCo would own half, at a cost of \$459 million) at or near the
2 Flint Creek site. This “brownfield” combined-cycle option would require
3 increased gas transmission to Flint Creek. The Company assumes that the
4 brownfield combined-cycle would also be operated out of economic order,
5 although the economic burden would be smaller than for the gas steam
6 plant, since a combined-cycle unit has lower running costs.

- 7 • Retiring Flint Creek and building a new 610-MW combined-cycle plant,
8 plus 116 MW of peaking duct-firing (of which SWEPCo would own half, at
9 a cost of \$509 million), at a greenfield site outside NW-AR. The Company
10 assumes that this option would require a new transmission line, at a cost of
11 \$193 million, of which SWEPCo would pay for about \$32 million, with the
12 remainder socialized across the Southwest Power Pool’s (SPP) transmission
13 region. This is Option 4.²

14 The Company’s economic analysis estimates the costs to SWEPCo, recog-
15 nizing that it jointly plans and dispatches its system with its sister utility Public
16 Service of Oklahoma (PSO), also a subsidiary of American Electric Power (AEP).
17 The Company and PSO are sometimes referred to jointly as the “AEP West” or
18 “AEP SPP” system.

19 **Q: Which aspects of that analysis did you review?**

²The \$193 million includes about \$31 million for lower-voltage local transmission that would be allocated 56% to SWEPCo, with the remainder presumably allocated to other utilities in the load pocket. This may be the same as the [redacted] million in [redacted] estimated in IR Staff 1-03_Attachment 2. The remaining \$162 million would be spread across all SPP transmission owners; SWEPCo reports that AEP-SPP’s share would be about 17% (from Mr. Weaver’s workpapers for his Table 6), and apparently uses this cost in its analysis. The Company’s load share would be about 9%. Including Public Service of Oklahoma overstates SWEPCo’s share of the investment by about \$13 million and its costs in 2016 by about \$18 million.

1 A: My review covered the following issues:

- 2 • The validity of assumptions made by SWEPCo in evaluating the three
3 alternatives (Options 2–4) that it proposed to the retrofit project. These
4 include the need for transmission were Flint Creek retired without
5 construction of equivalent-sized generation capacity in Northwest
6 Arkansas (NW-AR), and the need to run any new non-coal generation in
7 Northwest Arkansas out of economic order for transmission support absent
8 additional transmission investment.
- 9 • The Company’s forecast of natural-gas prices, and the effect of updating
10 those prices to reflect the current market on the economics of alternatives
11 to the continued operation of the Flint Creek coal unit.
- 12 • The following potential savings from replacement resource options that
13 SWEPCo did not consider:
 - 14 ○ energy-efficiency programs;
 - 15 ○ purchasing an existing gas combined-cycle plant to replace Flint
16 Creek, rather than building its own new combined-cycle unit;
 - 17 ○ a smaller amount of combined-cycle capacity;
 - 18 ○ a combined-cycle plant at the site of the Company’s Harry D.
19 Mattison plant in Tontitown, Arkansas;
- 20 • The reliability of the cost estimates for the near-term scrubber and for the
21 selective-catalytic-reduction (SCR) system that SWEPCo assumes will be
22 required in 2020 in its base case.

23 **Q: What are your conclusions?**

24 A: My conclusions are as follows.

25 First, SWEPCo has seriously exaggerated the effects of the NW-AR load
26 pocket on the cost of retiring the Flint Creek coal plant. It concludes that a new

1 transmission line would be needed were Flint Creek retired and replaced by a
2 greenfield combined-cycle plant (or other resources) outside the load pocket.
3 However, were the transmission line needed under those circumstances, it would
4 also probably be needed with the Flint Creek coal unit in operation. SWEPCo's
5 evaluation of the load pocket also leads it to impose minimum-load require-
6 ments on the gas steam plant and the brownfield combined-cycle plant that are
7 clearly excessive and grossly overstate the costs of those resources. The effect is
8 to make Options 2 and 3 appear less economic. As a result, no analysis incorpo-
9 rating the Company's transmission and minimum-load assumptions can be
10 considered reliable.

11 Second, the costs of all of the alternatives considered in SWEPCo's analysis
12 are highly dependent on natural-gas prices. The gas prices SWEPCo used—even
13 in the supposedly "low band" fuel-price case—are much higher than current
14 forward market prices. The Company's use of overstated gas prices overstates
15 the costs of all the alternatives to continued operation of Flint Creek on coal.
16 Without an analysis of the economics of alternatives under more reasonable gas
17 prices, it is impossible to conclude that the Project is in the public interest.

18 Third, SWEPCo did not consider the most-attractive alternatives to an exten-
19 sion of Flint Creek's life as a coal plant. The Company did not analyze a variety
20 of attractive options, including combinations of energy-efficiency programs,
21 purchased capacity, and gas-fired generation located at the Mattison site. Until
22 those options are compared to the Flint Creek coal plant, it is impossible to
23 conclude that the Project is in the public interest.

24 Fourth, the Company's estimates of the cost of the environmental retrofits
25 (both the Project and subsequent SCR installation) necessary to keep the coal
26 plant in operation are of doubtful quality.

1 **Q: How large an effect could correction of the problems you have identified**
2 **have on SWEPCo's analyses in this proceeding?**

3 A: Correcting those problems could well reverse the net benefit that SWEPCo asserts
4 for the Project. Table 1 summarizes the corrections for which I can estimate a
5 value.

6 Correction 1 is a simple updating of SWEPCo's analysis to be more con-
7 sistent with current conditions (a more detailed analysis would require a full
8 production costing model). Correction 2 adds in an estimate of the costs of an
9 alternative SWEPCo overlooked. Correction 3 corrects the inclusion of PSO's
10 costs in SWEPCo's computation. Correction 4 (which subsumes Correction 3)
11 represents a more-realistic view of the incremental need for the transmission
12 upgrades. Correction 5 is a rough adjustment to SWEPCo's low and poorly
13 documented SCR cost estimate. These corrections are derived below.

14 **Table 1: Alternatives Improved by Corrections to SWEPCo's Analysis**
15 (Millions of NPV Dollars)

Correction	Applicable to	Approximate Improvement
1. <i>Update Natural Gas Prices from SWEPCo Low-Band Price Case</i>	Option 2 Option 3 Option 4	\$104 \$95 \$81
2. <i>Purchase Existing Combined-Cycle Capacity</i>	Option 4	\$220–\$300
3. <i>Correct Allocation of Transmission Cost</i>	Option 4	\$24
4. <i>Remove Transmission Cost</i>	Option 4	\$42
5. <i>Increase SCR Cost by \$100/kW</i>	Options 2, 3, and 4	\$25

16 Since SWEPCo estimates that the cumulative present worth of continued
17 operation of the coal plant is less than Options 2–4 by \$227 million, \$148 mil-
18 lion, and \$274 million, respectively, these corrections would eliminate all of

1 SWEPCo's claimed benefit for the Project compared to the greenfield combined-
2 cycle Option 4, the vast majority of the claimed benefit over the brownfield
3 Option 3 (\$120 out of \$148 million), and over half of the claimed benefit over
4 the gas-steam Option 2 (\$106 out of \$227 million).

5 In addition to these roughly quantified adjustments, I have identified four
6 problems in the Company's analysis that I have not been able to quantify:

- 7 • the Company's modeling of the gas-steam and combined-cycle resources at
8 Flint Creek (Options 2 and 3) as operating at 70% of their rated capacity in
9 all hours of most months, at a large economic penalty;
- 10 • the omission of energy-efficiency programs as a resource to replace part of
11 Flint Creek's energy and capacity and relieve loads in NW-AR;
- 12 • the failure to consider replacement capacity at Mattison, which would both
13 allow the conversion of Mattison combustion turbines to combined-cycle
14 operation and avoid any need for the transmission line and a new gas
15 pipeline;
- 16 • the poor quality of SWEPCo's estimate of the cost of the scrubber-and-
17 baghouse combination (known as NID).

18 **Q: How do you recommend that the Commission respond to the Company's**
19 **petition in this docket?**

20 A: I recommend that the Commission decline to find the Project to be in the public
21 interest, unless and until the problems I have raised above are resolved. A
22 detailed review and appropriate revision of cost inputs and a more-realistic
23 consideration of alternatives would most likely show that the Project is not the
24 most cost-effective option for meeting demand in SWEPCo's territory as whole,
25 and the Northwest Arkansas region in particular.

1 **III. The Northwest Arkansas Load Pocket**

2 **Q: What does the Company claim about the Northwest Arkansas Load Pocket?**

3 A: The Company asserts that retirement of Flint Creek would require either

- 4 • construction of an equivalent amount of capacity in NW-AR, which
5 SWEPCo models as being at least 476 MW (for Flint Creek operating on
6 gas), generating at least 333 MW or more around the clock for [REDACTED]
7 months every year, or
8 • “an incremental bulk transmission investment...to ameliorate those
9 regional (NW-AR) constraints” (Weaver Direct, Table 5).

10 The Company suggests that the transmission investment can be “proxied”
11 as a 345-kV transmission line running from Fort Smith to Chamber Springs,
12 approximately 70 miles long, at a cost of \$193 million, comprising \$133 million
13 in 345-kV transmission, \$25 million in local equipment, \$11 million in over-
14 heads, and \$24 million in AFUDC. The Company estimates it would pay for
15 about \$37 million of this investment, plus overheads and AFUDC, consisting of
16 17% of SPP-level costs (\$23 million) with the remainder socialized across the
17 SPP transmission region and 56% of local costs (\$14 million) with the remainder
18 spread over other utilities in the AEP-SPP zone.³ With the overheads and AFUDC,
19 SWEPCo’s share would be about \$45 million. The Company reports that cost
20 recovery on that share of the transmission line through 2040 would have a 2011
21 present value of \$42 million.⁴

³Weaver Direct, workpaper Ex SCW-6 DETAIL WP (Opt 4_EHV Trans Cost Impact on CPW).

⁴Ibid. The Company appears to include overheads and AFUDC in the 14.65% fixed-charge rate it applies to transmission.

1 **Q: Does SWEPCo assert that these costs represent the least-cost solution for the**
2 **transmission issues in NW-AR?**

3 A: No. The Company concedes that this plan is only a proxy, rather than a well-
4 developed transmission solution.

5 Witness Hassink only suggests the 345kV line from Fort Smith to Chamber
6 Springs is a reasonable proxy for any transmission solution that may
7 ultimately be authorized by SPP to resolve NERC requirements in the NW-
8 AR area if Flint Creek were to be retired without local replacement. (APSC
9 Data Request 4-46)

10 Were some transmission needed (which is far from clear), the least-cost
11 plan may be less expensive than this proxy.

12 **Q: Did SWEPCo properly estimate its share of the transmission improvements?**

13 A: No. The Company appears to have over-estimated its share of the transmission
14 project, by using the “AEP-SPP” shares of the total costs.⁵ SWEPCo’s load shares
15 are 8.8% of SPP costs and 38.5% of local costs,⁶ which would imply a SWEPCo
16 share (without overhead or AFUDC) of

17
$$8.8\% \times \$133 + 38.5\% \times \$25 = \$21 \text{ million}^7$$

18 much less than the \$37 million that the Company estimates for the same set of
19 costs.

20 **Q: What problems does SWEPCo identify as arising if Flint Creek is retired and**
21 **the transmission project is not constructed?**

⁵Ex SCW-6 DETAIL WP (Opt 4_EHV Trans Cost Impact on CPW).

⁶Lachowsky’s workpaper “P 40 SPP trans allocation.”

⁷The present value of cost recovery through 2040 would be about \$24 million.

1 A: As explained in Attachments 1 and 2 to APSC Data Request 1-3, the problem
2 would arise for a second-contingency outage. As SWEPCo explains in its reply to
3 APSC Data Request 5-21,

4 The study provided as [Attachment 1] addressed single contingencies....
5 For the upcoming ten year period, this analysis found that no system
6 upgrades were necessary in order to retire the Flint Creek generator for
7 [these] contingencies.⁸ The study provided as [Attachment 2] addressed
8 multiple contingencies.... Since 320 MW of load shed was required in
9 order to be compliant, system upgrades would be required.

10

11 Attachment 2...looks at the Flint Creek generation being off and the
12 Mattison generation being on at the 2017 and 2022 summer peak. Then it
13 takes one line out of service. Then it checks to see how much load would
14 have to be shed preemptively, in order to avoid having the next worst
15 contingency overload any transmission facility above 110% of its emer-
16 gency rating.

17 Specifically, given the current transmission system and with Flint Creek
18 out of service, if one of the three 345-kV transmission lines serving the load
19 pocket were to go out of service, as much as 320 MW of load in NW-AR would
20 need to be shed to avoid complete collapse if a second 345-kV transmission line
21 or the Mattison generation were to go off line.

22 While Attachment 2 states that analyses were performed for 2017 and 2022
23 peak, it does not specify the year for which the 320-MW shortfall is identified.
24 The Company (APSC Data Request 5-21) says, “the result...that ‘up to approxi-
25 mately 320 MW of load in the Northwest Arkansas area may have to be shed
26 preemptively’ is based upon 2017 summer peak.”

⁸Indeed, there is no problem with any one contingency (e.g., line outage), without Flint Creek, even with no generation from any of the four units of Mattison.

1 **Q: Does SWEPCo’s treatment of the load pocket affect its analysis of the**
2 **alternatives?**

3 A: Yes. Each of the options, other than the retrofit of Flint Creek and continued
4 operation as a coal unit, has been burdened with unnecessary costs as a result of
5 the overstated load pocket concerns. The greenfield combined-cycle option
6 includes the \$37 million for the additional transmission line, while the brown-
7 field and gas-conversion options are required to operate at a minimum of 70%
8 of capacity in all hours for “several months of the year” (Rose Direct at 9).⁹ As a
9 result, ICF’s analysis concludes, “On average, over the 2016 to 2045 period,
10 dispatch averages 61% for the brownfield combined cycle and 38% for the gas
11 steam conversion option” (Rose Direct at 10). Rose reports that the greenfield
12 combined-cycle plant would run at a 24% capacity factor (Rose Direct at 10),
13 which would be typical of economic operation of combined-cycle plant in the
14 SPP region. A steam gas unit would typically run at a capacity factor much lower
15 than a modern combined-cycle plant, given the lower efficiency of this type of
16 unit. In interpreting the load-pocket constraints to require a minimum hourly
17 output of 70% of capacity, SWEPCo imposes very large costs of uneconomic
18 operation on the gas options in the load pocket.¹⁰

19 **Q: Are the Company’s claims about the load pocket supported by the record?**

⁹The Company appears to have specified the peak months in which the plants are required to run out of order ([REDACTED] only in a response classified as highly sensitive protected information (Company response to Sierra Club Data Request 1-165b).

¹⁰In SWEPCo’s analysis (replying to APSC Data Request 5-4), the brownfield combined-cycle plant runs at an average [REDACTED] % capacity factor. In that analysis, the greenfield combined-cycle plant runs at [REDACTED] %, while the gas steam plant also runs at [REDACTED] % capacity factor.

1 A: No. The Company’s principal analysis of the effects of Flint Creek retirement on
2 the NW-AR transmission system is contained in the Hassink attachments to
3 APSC Data Request 1-3, which describe the results of transmission modeling for
4 summer peaks in 2017 and 2022.¹¹ These analyses display a number of
5 peculiarities and inconsistencies, including the following:

- 6 • dismissing the possibility of rearranging dispatch to relieve transmission
7 overloads,
- 8 • overstating the number of hours and days on which loads reach levels at
9 which SWEPCo has identified problems,
- 10 • imposing more-stringent dispatch requirements on the brownfield com-
11 bined-cycle than on the gas steam plant, and
- 12 • ignoring the similarity in load flows following a forced outage of Flint
13 Creek and retirement of that unit.

14 **Q: Please describe SWEPCo’s treatment of the possibility of optimizing dispatch**
15 **to relieve transmission overloads.**

16 A: The overloading of transmission lines into a constrained area can be exacerbated
17 by the flow of power over the heavily loaded lines to allow power to flow out of
18 the area over other lines. Reducing those exports, or otherwise changing the
19 flow pattern, can reduce the overloading. This procedure is called transmission
20 loading relief (TLR), and it often would require changing dispatch of generation.
21 The Company says that it

¹¹These are the dates in Hassink’s Attachment 2. Attachment 1 does not specify a date, but APSC Data Request 5-21 clarifies that it was based on loads anticipated for 2022.

1 ...utilizes TLR [and Congestion Management Event] procedures to control
2 loadings on defined flowgates to maintain loadings within acceptable
3 levels. In some cases, transmission re-configuration options are also
4 available to mitigate thermal / voltage concerns. Re-configuration typically
5 occurs on a post-contingency basis but, depending on system conditions,
6 may also occur pre-contingency. Out of Order Merit Energy (OOME)
7 requests may also be issued to manually re-dispatch units that can assist in
8 facility loading control. If TLR/CME procedures, re-configurations options,
9 or OOME requests do not provide enough relief, AEP would shed load to
10 reduce loadings on the applicable facility until loadings are below the
11 defined emergency rating. (Sierra Club Data Request 1-209)

12 Hassink's Attachment 2 to APSC Data Request 1-3 says, "[REDACTED]
13 [REDACTED]
14 [REDACTED]
15 [REDACTED]." However, APSC Data Request 4-8 shows exports
16 from the load pocket that average [REDACTED] %–[REDACTED] % of NW-AR load and [REDACTED] %–[REDACTED] % of
17 NW-AR imports annually over 2009–2011.¹² The Company seems to have
18 prematurely dismissed the potential for reduced exports from NW-AR to relieve
19 transmission overloads in the load pocket. Dismissing the potential for TLR to
20 alleviate the load pocket problem allows SWEPCo to argue that excessive and
21 uneconomic operation is required for Options 2 and 3, and that the transmission
22 line is required for Option 4, making all three alternatives look less attractive
23 than they would actually be.

24 I have not been able to locate in the record which of the NW-AR tie lines
25 tend to be importing and which tend to be exporting at peak hours. However the
26 Company says, "Historically the Brookline–Flint Creek 345-kV line exports
27 power out of the area. Under contingency conditions, the line provides a

¹²Unfortunately, the codes used to identify the tielines in APSC Data Request 4-8 are not used in the transmission diagrams or other information that SWEPCo provided, and I have not been able to match the imports and exports with specific lines or interfaces.

1 minimal level of power import” (Sierra Club Data Request 1-203). This line
2 runs northeast from Flint Creek; increasing generation to the north and east
3 might reduce the export over this line and relieve the overloads on the lines from
4 the west.

5 To make matters worse, the Company’s transmission analysis assumes that
6 retirement of 514 MW at Flint Creek would result in generation increases of 257
7 MW at Wilkes in Northeast Texas and Oneta Energy Center near Tulsa, Okla-
8 homa, to the west and southwest from NW-AR, which would appear to increase
9 the flows over the lines subject to overloads (APSC Data Request 5-29). This
10 would not a realistic response to retirement of Flint Creek.

11 The Company has not shown whether generation increases in different
12 locations outside NW-AR would have smaller effects on transmission than
13 would the Wilkes-Oneta combination.

14 The Company’s assumption that additional output at Oneta and Wilkes
15 would replace Flint Creek’s is inconsistent with the rest of its analysis, in two
16 ways. First, the potential transmission problems that SWEPCo has identified
17 occur only at high loads and Oneta is a highly efficient gas combined-cycle unit,
18 so Oneta is unlikely to have over 250 MW of capacity sitting idle at peak hours.
19 More importantly for the present proceeding, SWEPCo assumes that retirement of
20 the generation at Flint Creek would result in addition of some new resource (a
21 greenfield combined-cycle plant in the option that the Company asserts would
22 create the need for transmission), so the major difference in peak-hour dispatch
23 due to Flint Creek’s retirement would be that the replacement resource would
24 operate. The Company could base its selection of the location of that greenfield
25 combined-cycle plant, in part, to reduce the stress on the transmission system.

1 **Q: Did SWEPCo overstate the number of hours and days on which loads reach**
2 **levels at which transmission problems might occur?**

3 A: Yes. The problems identified by the Company in Hassink’s Attachment 2 to
4 APSC Data Request 1-3 only occur at load levels exceeding the capacity of the
5 existing transmission lines. SWEPCo asserts that a 320-MW shortfall would
6 occur with the loads and generation modeled for 2017 (APSC Data Request 5-
7 21), but does not identify the peak load level that is 320 MW higher than the
8 transmission capacity. Given the discussion of the loads used for 2022 in
9 Hassink’s Attachment 1 to APSC Data Request 1-3, and of the loads SWEPCo
10 currently projects for 2018 and 2023, it is my opinion that the 320 MW shortfall
11 was computed for a peak loads around [REDACTED] MW. At lower demand levels, less
12 load would need to be shed to bring the load below the carrying capacity of the
13 system with two 345-kV lines out of service. For demands of less than about
14 [REDACTED] MW-79% of peak-no load shedding would be needed.¹³ In 2009–2011, an
15 average of [REDACTED] hours on an average of [REDACTED] days had loads greater than 79% of
16 peak. Consequently load-shedding would be needed for only about 7% of the
17 hours or 23% of the days for which SWEPCo requires the gas-steam and brown-
18 field combined-cycle plants to operate. During these high-load hours, the
19 combined-cycle unit would likely run for economic reasons; even the gas-steam
20 plant would run economically at many of these hours. Hence, SWEPCo’s esti-
21 mates of the amount of uneconomic operation of the brownfield and gas-steam
22 plants are greatly overstated.

¹³If the statement refers to any higher peak load, the level at which any shedding might be required would be higher and occur further in the future.

1 **Q: Did the Company impose more-stringent dispatch requirements on the**
2 **brownfield combined-cycle plant than on the gas steam plant?**

3 A: Yes. The Company requires both the 476-MW gas-steam plant in Option 2 and
4 the 608-MW combined-cycle plant in Option 3 to operate at 70% of capacity,
5 even though that is 333 MW for the gas-steam unit and 426 MW for the com-
6 bined-cycle unit, and even though the combined-cycle plant would generally be
7 able to ramp up faster after a first contingency than the gas-steam plant. The
8 70% minimum-dispatch requirement is clearly arbitrary.

9 **Q: Does the Company's position adequately address the similarity in load**
10 **flows following a forced outage of Flint Creek and retirement of that unit?**

11 A: No. The situation in NW-AR without Flint Creek at a particular load level is the
12 same whether Flint Creek has been retired or is simply offline for a few days of
13 repairs. The Company

14 has not designed a Special Protection Scheme for NW Arkansas...because
15 the need to preemptively shed load that witness Hassink describes in his
16 testimony is predicated upon the retirement of Flint Creek Generating
17 Plant. The Flint Creek Generating Plant is presently an in-service plant,
18 therefore, there is no need for a Special Protection Scheme. (Sierra Club
19 Data Request 1-212)

20 Instead, if Flint Creek is out of service and SWEPCo Arkansas load exceeds

21 [REDACTED], the Company will [REDACTED]

22 [REDACTED].¹⁴ This is apparently a rare occurrence, since [REDACTED]

23 [REDACTED] in 2009–

¹⁴Even when Flint Creek is operating, SWEPCo's procedures require it to [REDACTED]
when SWEPCo Arkansas load exceeds [REDACTED]. (IR AG 2-8,
Attachment 1) It is not clear how total load in SWEPCo Arkansas, which includes some of the load
in NW-AR and some load elsewhere, relates to total load in NW-AR.

1 2011. This shows that the absence of Flint Creek capacity, even at peak demand,
2 does not require new transmission lines, 476 MW of additional generation, or
3 the operation of 333 MW in all hours at 70% of full capacity.

4 If SWEPCo's position on the need for load relief in NW-AR following Flint
5 Creek's retirement were correct, similar investments would be required even
6 with Flint Creek in continued service, probably at current load levels but
7 certainly at loads anticipated over the next several years.

8 **Q: Is SWEPCo's position that the retirement of Flint Creek would require either**
9 **(1) the transmission additions or (2) the construction of at least 476 MW of**
10 **new capacity in NW-AR in any way plausible?**

11 A: No. Any capacity or transmission reinforcement required with the retirement of
12 Flint Creek would also be required with Flint Creek remaining in service and
13 cannot be considered a cost of Flint Creek's retirement for the Project alterna-
14 tives evaluated by the Company.

15 **Q: Given the information that SWEPCo has provided, is it reasonable to expect**
16 **the NW-AR load pocket would need a minimum of 333 MW of capacity**
17 **operating in the load pocket for [REDACTED] the hours of the year?**

18 A: No. That operational requirement would clearly be unnecessary and inconsistent
19 with current practice.

20 **Q: What would be the effect of correcting these overstatements about the need**
21 **for new transmission and minimum run time have on SWEPCo's analysis of**
22 **the alternatives to Flint Creek?**

23 A: If the transmission upgrade is not part of the cost of replacing Flint Creek with a
24 greenfield combined-cycle plant, either because the line is not needed without
25 Flint Creek or because the line is needed even with Flint Creek in operation, the
26 investment for the greenfield combined-cycle plant (Option 4) would be reduced

1 by about \$173 million, and the present value of the cost of that option would be
2 reduced by about \$42 million (Weaver Direct, Exhibit SCW-6 and supporting
3 detail workpaper in APSC Data Request 1-3). Simply correcting SWEPCo's
4 inclusion of PSO's share of the transmission costs would reduce the present value
5 of Option 4 by about \$13 million.

6 For Options 2 and 3, SWEPCo does not include the transmission line in its
7 estimates but does include significant amounts of uneconomic energy genera-
8 tion, most of which would not be necessary, as explained on page 19 above.
9 Estimating the magnitude of those excess costs would require a new modeling
10 run, with more realistic operating constraints.

11 **IV. Overstatement of Natural-Gas Prices**

12 **Q: Why are natural-gas prices important in the evaluation of the Project?**

13 A: All three options that SWEPCo considers as alternatives to continued burning of
14 coal at Flint Creek are natural-gas-fired generation. One major factor favoring
15 the selection of the project is the difference in fuel costs per MWh between
16 Option 1 (Flint Creek coal) and the three gas-burning alternatives (Options 2, 3,
17 and 4). All else equal, lower gas fuel costs per MMBtu (and hence per MWh)
18 will shrink the cost differentials among these options. Differences in fuel costs
19 comprise 120% of the difference in present value that SWEPCo reports between
20 Options 1 and 2, more than 200% of the difference between Options 1 and 3,
21 and 90% of the difference between Options 1 and 4. Thus, overstating gas prices
22 will disproportionately inflate the overall costs of gas-fired options compared to
23 coal.

24 **Q: Are the natural-gas prices in SWEPCo's analysis reasonable?**

1 A: No. The Company's natural-gas forecasts might have been reasonable when
2 prepared last summer and fall, but the natural-gas market has shifted sub-
3 stantially in the last several months.

4 The shifts are due to development of large amounts of non-conventional
5 gas resources and expectations that additional such resources will continue to be
6 available at low cost for many decades. In response to a long-term surplus of
7 domestic natural gas, projects to import liquefied natural gas into North America
8 have been cancelled, existing import facilities are being converted to export gas,
9 and new export projects are under development.

10 These changes in expected natural-gas prices must be reflected in an
11 updated analysis to provide the Commission with a sound basis on which to
12 base its determination of whether the proposed retrofit is in the public interest.


13 **Q: How did SWEPCo and ICF develop their forecasts?**

14 A: The Company's gas-price forecast was part of a long-term projection of
15 commodity prices developed by the AEP Fundamental Analysis group in
16 September 2011 (Weaver Direct at 41), using the U.S. Energy Information
17 Administration's Annual Energy Outlook forecast from April 2011 and con-
18 sultant forecasts from May (see APSC Data Request 1-3, workpaper "Ex SCW-
19 4(2) WP (NG-HH Consensus Pricing)"). The market forward prices represent
20 estimates of future costs on which markets are betting actual money. The ICF
21 natural-gas-price forecast was apparently from an internal analysis from
22 [REDACTED] 2011 benchmarked on Henry Hub forward prices from [REDACTED] 2011
23 (Rose Direct Exhibit JLR-2 at 56-57), although other responses (Sierra Club
24 Data Requests 1-175 and 1-179) suggest that the forecast was prepared in
25 [REDACTED].

1 The ICF forecast explicitly treats the NYMEX forwards for Henry Hub as an
2 input or benchmark (Rose Direct, Attachment JLR-2 at 56).

3 Figure 1 shows the Company’s base forecast for natural gas at Henry Hub
4 (the “Fleet Transition–CSAPR” case) and its lowest Henry Hub forecast (the
5 “Fleet Transition–CSAPR: Lower Band” case), along with Henry Hub forwards
6 from September 2011, November 2011 and June 19 2012.

1 **Figure 1: Henry Hub Prices, SWEPCo Forecasts and Forwards over Time**



3 Figure 1 shows that SWEPCo’s base case was very similar to the forwards
4 prices from September and November. Current forwards are not just lower than
5 SWEPCo’s base case, but also lower than the Company’s low-band forecast.
6 Indeed, the current natural-gas forwards average about as far below SWEPCo’s
7 low-band case as its low-band case is below the Company’s base forecast.

8 While Mr. Weaver says that his low-band case “bounds the low-end of the
9 BASE case with plausible fuel, emissions and energy pricing varying by approxi-
10 mately –1.0 standard deviation” (Weaver Direct, Table 7), his low forecast only
11 reached half way to reality.

12 **Q: Can you revise SWEPCo’s natural-gas-price forecast to reflect current condi-**
13 **tions in the long-term market?**

14 **A:** Yes. From 2016 through 2024, I updated SWEPCo’s base forecast of natural gas
15 prices at Henry Hub from the fall-2011 prices SWEPCo used to the annual

1 average of closing NYMEX forward prices on June 19 2012. These prices are
 2 shown in Table 2, along with the ratio of current forwards to SWEPCo's base
 3 forecast.

4 **Table 2: SWEPCo Base Gas Forecast, Current Forwards, and Extrapolation**

	SWEPCo Base Forecast	6/19/12 Forwards	Price Ratio	Updated Forecast
2013	\$4.85	\$3.46	71.4%	\$3.46
2014	\$5.31	\$3.84	72.2%	\$3.84
2015	\$5.45	\$4.04	74.1%	\$4.04
2016	\$5.91	\$4.20	71.1%	\$4.20
2017	\$6.05	\$4.37	72.2%	\$4.37
2018	\$6.25	\$4.54	72.7%	\$4.54
2019	\$6.41	\$4.75	74.2%	\$4.75
2020	\$6.46	\$4.98	77.0%	\$4.98
2021	\$6.70	\$5.19	77.5%	\$5.19
2022	\$7.02	\$5.42	77.2%	\$5.42
2023	\$7.23	\$5.69	78.7%	\$5.69
2024	\$7.49	\$5.96	79.6%	\$5.96
2025	\$7.74		80.7%	\$6.24
2026	\$7.85		81.8%	\$6.41
2027	\$8.04		82.8%	\$6.66
2028	\$8.23		83.9%	\$6.91
2029	\$8.42		85.0%	\$7.15
2030	\$8.54		86.0%	\$7.34
2031	\$8.65		87.1%	\$7.53
2032	\$8.76		88.2%	\$7.73
2033	\$8.88		89.2%	\$7.92
2034	\$9.00		90.3%	\$8.13
2035	\$9.13		91.4%	\$8.34
2036	\$9.25		92.4%	\$8.55
2037	\$9.37		93.5%	\$8.76
2038	\$9.50		94.5%	\$8.98
2039	\$9.62		95.6%	\$9.20
2040	\$9.75		96.7%	\$9.43

Note: For those years after the NYMEX Henry Hub forwards end in 2024, I extrapolated the price ratio at the 1.07% average annual increase from 2016 to 2024.

5 My updated forecast exceeds SWEPCo's low-band forecast in 2032.

1 This revision is intended to represent current market indications for future
2 prices. It is an update to SWEPCo's base case. An updated low-band case would
3 be even lower than my revised base case.

4 **Q: How would this updated forecast of the cost of natural gas affect the costs**
5 **of the different options?**

6 A: A comprehensive analysis of the effects of revised natural-gas forecasts on the
7 costs of the different natural-gas-fired alternatives would require rerunning
8 SWEPCo's costing models. Instead I estimated the effect of revising the natural-
9 gas-price forecasts by computing the reduction of fuel costs for each of the
10 natural-gas-fired options, from both SWEPCo's base and low-band natural-gas-
11 price forecasts. For each year, I multiplied the difference in natural-gas price
12 between SWEPCo's forecast and my updated gas-price forecast by the energy
13 output from the option's replacement capacity (Flint Creek converted to natural-
14 gas firing, a brownfield combined-cycle at Flint Creek, or a greenfield com-
15 bined-cycle outside the NW-AR load pocket) reported in response to APSC Data
16 Request 5-4.¹⁵ I did these computations directly from SWEPCo's base forecast,
17 and indirectly from SWEPCo's low-band natural-gas forecast; for the latter, I
18 compute the difference in costs from the SWEPCo low-band natural-gas price to
19 current prices, add SWEPCo's estimate of the difference in system costs between
20 its base and low-band natural-gas forecasts, and add back the \$3 million effect
21 of the reduction in coal prices between SWEPCo's base and low fuel forecasts.
22 The results of these computations are summarized in Table 3.

¹⁵The Company designated its modeled forecast of the annual energy output by unit as confidential, so I provide only the present-value summary of my results in this testimony.

1 **Table 3: Cost Reductions from Revising Gas Forecast** (Millions of NPV Dollars)

Option	Reduction from SWEPCo ^a		SWEPCo Difference from Base to Low Band ^b	Update from Base, via SWEPCo Low Band ^c
	Base	Low Band		
2 Flint Creek Gas	\$97	\$36	\$68	\$104
3 Brownfield CC	\$137	\$46	\$49	\$95
4 Greenfield CC	\$92	\$31	\$50	\$81

^aBase and Low Band from Table 2, Exhibit SCW-4, and APSC Data Request 5-4

^bExhibit SCW-6, net of \$3M due to coal price change

^cSum of low band and SWEPCo difference

2 Table 3 presents the following two estimates of the cost reduction for each
3 option if the updated gas prices are substituted for SWEPCo’s base forecast:

- 4 • my estimate of the reduction from SWEPCo base prices to updated prices,
5 using the replacement plant’s energy in SWEPCo’s base-price case (“Base”)
- 6 • the sum of the SWEPCo’s estimate of the cost reduction from its base to
7 low-band prices and my estimate of reduction from SWEPCo low-band
8 prices to updated prices, using the replacement plant’s energy in SWEPCo’s
9 low-band case (rightmost column).

10 The two methods in Table 3 agree fairly closely for Options 2 and 4,
11 suggesting that changes in gas prices mostly affect the cost of running the
12 options’ replacement capacity. For Option 3, using SWEPCo’s low-band case
13 results in a smaller reduction than does working directly from SWEPCo’s base
14 case. That difference probably arises due to a combination of increased eco-
15 nomic dispatch of the brownfield combined-cycle plant with lower fuel prices,
16 redispatch of other units, and changes in wholesale transactions.

1 **V. Alternative Resource Options**

2 **Q: What additional resource alternatives have you identified, beyond those**
3 **considered by SWEPCo?**

4 A: I have identified the following additional resource options:

- 5 • energy-efficiency programs,
- 6 • purchasing an existing gas combined-cycle plant to replace Flint Creek,
7 rather than building its own new combined-cycle unit,
- 8 • a smaller amount of combined-cycle capacity,
- 9 • a combined-cycle plant at the Mattison site.

10 I discuss these options in the next three sections.

11 **A. *Energy Efficiency***

12 **Q: How would increased energy-efficiency programs create an alternative re-**
13 **source for replacing Flint Creek and avoiding the costs of the environmental**
14 **retrofits?**

15 A: Energy-efficiency programs beneficially reduce the following loads:

- 16 • energy consumption and associated line losses, offsetting the reduction in
17 energy produced associated with the retirement of Flint Creek;
- 18 • peak loads, associated line losses, and the need for reserves, offsetting the
19 loss in system capacity due to retirement of Flint Creek;
- 20 • loads in the NW-AR load pocket, reducing the need for transmission and
21 generation for that area;
- 22 • system loads and NW-AR loads more at high-load times (such as extra-
23 ordinarily hot days), when the reductions are most needed and valuable.

24 In addition to these benefits related to the specific concerns addressed in
25 SWEPCo's economic analysis, energy-efficiency programs also reduce local

1 transmission-and-distribution costs. Reducing energy requirements can also
2 reduce the cost of meeting environmental constraints, such as the seasonal NOx
3 limits in all three states served by SWEPCo (Arkansas, Louisiana, and Texas) and
4 the annual SO₂ and NOx limits in Texas under the Cross State Air Pollution
5 Rule.

6 **Q: How much energy and peak savings does SWEPCo currently project from its**
7 **energy-efficiency programs?**

8 A: In Arkansas, SWEPCo is projecting annual incremental demand savings of about
9 0.77% of peak load in 2012, falling to about 0.5% of peak load from 2013
10 through 2016, averaging about 0.3% from 2017 to 2020, and falling off to zero
11 by 2026.¹⁶ In the rest of its retail system, SWEPCo projects annual incremental
12 savings of about 0.1% of load in 2013, about 0.2% in 2014 to 2020, falling to
13 near zero thereafter.¹⁷

14 Cumulatively, this amounts to about 24 MW of post-2012 savings for
15 SWEPCo Arkansas and another 24 MW for the rest of SWEPCo through 2016, and
16 35 MW for SWEPCo Arkansas and another 51 MW for the rest of SWEPCo
17 through 2020. About 65% of SWEPCo's Arkansas load is in NW-AR, so a similar
18 share of the energy-efficiency savings should be in the load pocket, as well.

19 While SWEPCo has not provided as much detail for its projected energy
20 savings (either the breakdown between Arkansas and the rest of the utility or the

¹⁶The 2012 savings are consistent with the Commission's target of 0.75% savings.

¹⁷These data are from Weaver's Exhibit SCW-2, the supporting workpapers, and Sierra Club Data Request 1-187. The Company has provided publicly its forecast of Arkansas retail peak load and both retail and system-wide energy-efficiency demand savings, but not its forecast of retail load in the rest of the system. Hence, I describe these projections in only the most general terms.

1 breakdown between wholesale and retail), they appear to be of similar
2 magnitude.

3 **Q: How much savings are the leading utilities and regulatory jurisdictions**
4 **achieving from their energy-efficiency programs?**

5 A: The utilities and other program administrators that have seriously invested in
6 energy-efficiency have achieved and are planning to continue achieving annual
7 savings in the range of 1% to 2% of load. See the report from the Green Energy
8 Economics Group, attached as Exhibit PLC-2 (specifically Tables 1, 4, and 6),
9 for more detail.

10 **Q: If SWEPCo ramped up its energy-efficiency programs to those levels, by how**
11 **much might it reduce its load?**

12 A: Were SWEPCo to increase its annual incremental energy-efficiency savings to

- 13 • 1% in 2013, rather than decreasing them,
14 • 1.25% in 2014, and
15 • 1.5% for 2015–2020,

16 and the Texas and Louisiana annual incremental savings to

- 17 • 0.25% in 2013,
18 • 0.5% in 2014,
19 • another 0.25% increase each year through 1.25% in 2017, and
20 • 1.5% in 2018–2020,

21 the Company could reduce its peak load by about 80 MW in 2016 and 280 MW
22 in 2020, of which about 32 MW and 20 MW would be in Arkansas and NW-
23 AR, respectively by 2016, rising to about 84 MW and 55 MW, respectively by
24 2020. All of these figures are in addition to the energy-efficiency savings in the
25 Company's forecast.

26 **Q: How much would these savings cost?**

1 A: The experience of other jurisdictions indicates that the costs of achieving
2 savings of this magnitude would be on the order of 4¢–5¢/kWh saved. See
3 Exhibit PLC-2, Table 15, for more detail.

4 **B. *Purchase of Natural-Gas Combined-Cycle Capacity***

5 **Q: Were SWEPCo to seek the opportunity to purchase an existing gas com-
6 bined-cycle plant from a merchant owner, would it be likely to find one?**

7 A: Yes. I have identified approximately 6,100 MW of combined-cycle capacity
8 owned by merchant generators in the Southwest Power Pool and well-inter-
9 connected neighboring Entergy Arkansas territory. See Table 4 below. This
10 capacity is generally not committed to serving load, and is sold in the spot
11 market or under short-term contracts.

12 The first four plants in Table 4, Oneta, Dogwood, Eastman, and Green
13 Country (along with the Harrison plant that was sold to Texas coops in Dec-
14 ember 2010), are listed as being available to meet generation shortfalls in the
15 modeling used to develop the Southwest Power Pool’s 2012 Integrated
16 Transmission Plan Near-Term Assessment Report (January 9, 2012; Table 6.3).
17 The two Arkansas plants, Pine Bluff and Union Power, are in the Entergy con-
18 trol area, geographically and electrically adjacent to SWEPCo.

19 [REDACTED]
20 [REDACTED]
21 [REDACTED] Clearly, there are willing
22 sellers.

1
2

Table 4: Merchant Combined-Cycle Capacity in SPP or Entergy’s Arkansas Territory

Plant and Owner	State	Summer Net MW	2010 Capacity Factor
<i>Oneta Energy Center^a</i> Calpine Central LP	Okla.	886	31%
<i>Dogwood Energy Facility^b</i> Dogwood Energy LLC	Mo.	449	15%
<i>Eastman Cogeneration Facility</i> Eastman Cogeneration LP	Tex.	402	55%
<i>Green Country Energy^c</i> Green Country LLC	Okla.	263	32%
<i>Coughlin Power Station</i> Cleco Evangeline LLC	La.	732	4%
<i>Kiamichi Energy Facility</i> Kiowa Power Partners LLC	Okla.	1,178	31%
<i>Pine Bluff Energy Center</i> Pine Bluff Energy LLC	Ark.	192	85%
<i>Union Power Station</i> Union Power Partners LP	Ark.	2,020	41%
Total		6,122	32%

^a The 886 MW at Oneta Energy Center is net of a 200-MW sale to Southwestern Public Service Company (Calpine 2010 Annual Report at 66) through May 2019.

^b The 449 MW at Dogwood Energy Facility is net of the recent sales of a total of 165 MW to municipal utilities

^c The 263 MW at Green Country Energy is net of the 520 MW PPA with Public Service Company of Oklahoma that will be in effect from June 2012 through February 2022 (Exelon 10-K at 295).

3
4
5
6
7

In addition to the combined-cycle capacity listed above in Table 4, merchant generators also own some 826 MW of modern combustion turbine capacity in Louisiana and Missouri that may be available to provide SWEPCo with peaking energy and reserve capacity. As noted below in Section V.C, SWEPCo’s model selects combustion turbines whenever it is allowed to do so.

8
9

Q: Have other merchant generators sold combined-cycle plants in SPP and adjacent areas?

10
11

A: Yes. About twenty such merchant combined-cycle gas plants have sold in SPP and elsewhere in Texas and Arkansas in recent years, as shown below in Table

1 5. These past sales provide some indication of the market value of combined-
 2 cycle plants.

3 **Table 5: Sales of Combined-Cycle Plants In and Around the Southwest Power Pool**

Seller	Plant Name	State	Closing Date	Sold	Summer Capacity (MW) ^a	Acquirer	Purchase Price	
							\$M	\$/kW
NRG Energy	McClain	Okla.	7/9/04	77%	377	Okla. G&E	\$160	\$425
CLECo	Perryville	La.	6/30/05	100%	831	Entergy LA	\$170	\$205
Central Mississippi Generating	Attala	Miss.	3/31/06	100%	500	Entergy MS	\$88	\$176
Calpine	Aries/Dogwood	Mo.	2/7/07	100%	677	Kelson	\$234	\$345
Cogentrix Energy	Ouachita	La.	5/4/07	100%	904	Entergy AR	\$198	\$219
Calpine	Acadia Energy	La.	8/17/07	50%	1,376	Cajun Gas Energy	\$189	\$137
GE Energy Financial Services	Green Country	Okla.	10/2/07	100%	904	J-Power USA Generation	\$240	\$265
Cogentrix	Southaven	Miss.	5/9/08	100%	904	TVA	\$461	\$510
Kelson	Redbud	Okla.	9/30/08	100%	1,338	Okla. G&E	\$852	\$637
Tennessee Valley Authority	Southaven	Miss.	10/6/08	70%	633	Seven States Power	\$345	\$545
Acadia Power	Acadia 1	La.	Feb '10	100%	580	CLECo	\$304	\$524
Kelson	Cottonwood	Texas	Aug '10	100%	1,279	NRG Energy	\$525	\$410
Entergy	Harrison	Texas	Dec '10	61%	550	East and North Texas Coops	\$219	\$654
PSEG	Odessa	Texas	1/13/11	100%	1,000	High Plains Diversified Energy	\$335	\$335
PSEG	Guadalupe	Texas	1/13/11	100%	1,000	Wayzata Investment	\$351	\$351
Acadia Power	Acadia 2	La.	4/29/11	100%	580	Entergy LA	\$300	\$517
Sequent	Wolf Hollow	Texas	5/13/11	100%	720	Exelon	\$305	\$424
Kelson	Magnolia	Miss.	Aug '11	100%	863	TVA	\$436	\$505
KGen Partners	Hinds	Miss.	2012	100%	520	Entergy AR	\$206	\$396
KGen Partners	Hot Spring	Ark.	2012	100%	630	Entergy MS	\$253	\$408
Kelson	Dogwood	Ark.	3/11	{ 8.2% 12.3% 6.6%	50 75 40	MJMEUC Independence P&L Kansas Power Pool	\$46	\$613
GDF Suez	Hot Spring	Ark.	5/13/11	100%	641	AECC	\$240	\$374

^aSummer capacity reported by owner or U.S. EIA.

1 The average of the transaction prices in 2011 and 2012 was about
2 \$420/kW, or about \$470/kW excluding the plants in the Electric Reliability
3 Council of Texas territory.

4 [REDACTED]

5 [REDACTED]

6 [REDACTED]

7 [REDACTED]

8 **Q: Have the owners of Flint Creek received offers or expressions of interest**
9 **from the owners of combined-cycle plants for sale of ownership or long-**
10 **term capacity entitlements in the plants?**

11 A: Yes. Those offers to SWEPCo are discussed in replies to Sierra Club Data
12 Request 1-147 and 1-148 and to AECC in APSC Data Request 7-1 and 7-2.

13 **Q: Does SWEPCo accept that these recent transactions indicate the likely cost of**
14 **purchasing capacity from one or more of the eight plants in Table 4?**

15 A: No. In response to the Staff’s question about the significance of the agreement
16 under which AECC would purchase the Hot Springs Power Plant, SWEPCo
17 disputes the relevance as a market indicator of the price that GDF Suez offered
18 for the Hot Springs plant:

1 ...the Company does not believe that the recent offer for sale of GDF Suez'
2 Hot Springs Power Plant provides a valid data point for the availability of
3 purchasing merchant CC generation in or near SPP. First, with the exception
4 of the Dogwood plant, the Company is not aware of other owners of mer-
5 chant CC generation in or near SPP starting any sale processes. The
6 Dogwood facility recently sold 75 MW of capacity for \$612/kW to a group
7 of municipal utilities in Kansas. So the Hot Springs plant does not appear to
8 provide a valid data point on what else may be available. Second, the
9 willingness or desire of the owner of merchant CC generation to begin a
10 sale process depends largely on the specific circumstances of the unit, such
11 as whether or not the owner has entered into any long-term contracts for
12 capacity or energy from the unit. GDF Suez' offer reflects the circumstances
13 at the Hot Springs plant; nothing can be inferred about other merchant CC
14 generation from GDF Suez' desire to sell the Hot Springs plant. (APSC Data
15 Request 5-7)¹⁸

16 Notwithstanding the Company's preference for referring to the more
17 expensive Dogwood sale and its assertion that the Hot Springs sale is irrelevant,
18 both of these sales were at prices far below SWEPCo's estimate of the cost of a
19 new combined-cycle plant. And despite SWEPCo's implication that the offer
20 from GDF Suez was related to "the specific circumstances of the unit," many
21 merchant generators have sold ownership or long-term capacity contracts
22 (including parts of three plants in Table 4). Others (including some owners of
23 capacity in Table 4) have offered capacity unsuccessfully.

24 The plants listed in Table 4 and Table 5 are efficient modern combined-
25 cycle units. Dogwood, for example operated at about 7,700 Btu/kWh heat rate in
26 2010, even though it was running at a disadvantageously low capacity factor of
27 only 16%.¹⁹ Any of those units would be likely to remain in operation much
28 longer than the analysis period used by SWEPCo.

¹⁸The Company cites only a portion of the Dogwood sale.

¹⁹Dogwood consists of two Siemens-Westinghouse Model 501F combustion turbines and a steam cycle.

1 **Q: Were SWEPCo to purchase an existing combined-cycle plant, rather than**
2 **build a new one, how would that change the economics of the greenfield**
3 **combined-cycle option?**

4 A: The Company estimates costs of the greenfield combined-cycle unit (Option 4),
5 excluding AFUDC, at \$1,287/kW without the duct firing and \$1,084/kW counting
6 the duct-firing capacity, in 2011 dollars (Weaver Direct, Table 6). With AFUDC,
7 these values would be about \$1,468/kW and \$1,236/kW, respectively.²⁰ Since
8 these costs are in 2011 dollars, they should be comparable to recent sales prices.

9 By comparison, the sales of existing combined cycle capacity since 2010
10 have ranged from \$335/kW to \$613/kW, while the average for SPP and other
11 Arkansas sales was \$470/kW.

12 The difference in cost between the greenfield combined-cycle plant and the
13 recent sales is roughly \$600–\$1,000/kW, depending on whether the reported
14 capacity of recent sales include duct burners, and whether the average or highest
15 price is used in the comparison. For a purchase equal to SWEPCo's share of the
16 greenfield combined-cycle plant, 305 MW without duct burners or 363 MW
17 with, this would represent a savings of \$220–\$300 million in capital costs,
18 wiping out most or all of the \$274 million present-value advantage calculated by

²⁰This computation includes \$131 million of nominal AFUDC (from Mr. Weaver's workpapers for Table 6). This is \$110 million in 2011 dollars (using SWEPCo's 3.5% escalation rate), and thus \$181/kW without counting the duct firing and \$152/kW with the duct firing. SWEPCo estimates the costs of the greenfield combined-cycle plant in 2016, with AFUDC, to be about \$1,650/kW (without duct firing) and \$1,386/kW (with duct firing).

1 SWEPCo for Flint Creek coal versus the greenfield combined-cycle plant under
2 the base commodity-price scenario (Weaver Direct, Exhibit SCW-6).²¹

3 **C. Other Promising Generation Construction Options**

4 **Q: What other generation construction options should the Company have**
5 **considered?**

6 A: The Company should have compared the costs of continued operation of Flint
7 Creek to a smaller amount of combined-cycle capacity and a combined-cycle
8 plant at the Mattison site.

9 **Q: Why should the Company have compared the Flint Creek retrofit with a**
10 **smaller amount of combined-cycle capacity?**

11 A: In its analysis, SWEPCo compares the economics of its 259-MW share of Flint
12 Creek to 304 MW (Option 3) or 305 MW (Option 4) of a gas combined-cycle
13 plant, plus 58 MW of duct-firing capacity, all in 2016. There are two reasons to
14 believe that this oversized replacement plant would be less economic than one
15 more appropriately sized to replace Flint Creek

16 First, the Company's modeling runs indicate that the least-cost additions
17 are always combustion turbines. SWEPCo forces the combined-cycle plants into
18 the analysis to replace Flint Creek in 2016, and in 2020, to replace Welsh 2,
19 which must retire in 2015. This is true for all options, all fuel prices, and all
20 carbon prices. Since the economic optimization does not choose additional

²¹Each dollar of avoided capital cost saves about \$1.45 in present value of revenue requirements over thirty years, but this increase is offset by a roughly equal reduction from discounting the costs from 2016 back to 2011.

1 combined-cycle additions, it is likely that the additional 45 MW of extra com-
2 bined-cycle capacity is also not economic.

3 Second, while the extra 45 MW of combined-cycle capacity and the 58
4 MW of peaking duct-firing are added in 2016, the Company's model does not
5 select any additional capacity (other than the forced combined-cycle in 2020)
6 until 2026 with Flint Creek (Options 1 and 2) or 2027 with the larger replace-
7 ment combined-cycle options (Options 3 and 4). By over-sizing the combined-
8 cycle plant and adding the duct-firing capacity, SWEPCo has included costs
9 starting in 2016 for capacity that the planning model would not add until 2026.

10 The Company did not evaluate, or estimate the costs of 200 MW or 400
11 MW of gas combined-cycle capacity at the Flint Creek site. (Sierra Club Data
12 Request 1-107).

13 **Q: Why should SWEPCo have compared the Flint Creek retrofit with a**
14 **combined-cycle plant at the Mattison site?**

15 A: The Mattison site has gas supply and is in the NW-AR load pocket. The four
16 existing General Electric Model 7EA combustion turbines at the plant have a
17 total summer capacity of 300 MW. SWEPCo's original 2006 announcement of
18 the plant projected the construction of up to 480 MW of peaking generation.²²
19 The Company has also said (in Exhibit WMJ-2, PUCT Docket No. 37364, at
20 161), "The site was designed to have up to eight GE 7E" combustion turbines
21 "but the constructed size was scaled back to four [units] to match forecasted
22 demand," suggesting that additional gas supply is available at the site. In
23 addition, each pair of existing General Electric 7EA combustion turbines can be

²²"SWEPCo Announces Plans for New Generation" AEP news release, May 31 2006
<http://www.aep.com/environmental/news/?id=1286>, accessed June 27 2012.

1 incorporated into a combined-cycle plant, adding about 80 MW of steam-turbine
2 capacity. Converting the two pairs of Mattison combustion turbines to combined-
3 cycle operation would add about 160 MW of capacity in the load pocket,
4 without requiring any gas pipeline capacity beyond that currently dedicated to
5 the Mattison plant.

6 The Company has completely ignored the possibility of developing
7 generation at Mattison. “No cost estimates of the ‘attendant gas supply require-
8 ments’ for 200 MW, 400 MW or 600 MW of gas combined-cycle capacity at the
9 Mattison site were prepared. These scenarios were not evaluated.” (Sierra Club
10 Data Request 1-108)

11 **Q: Other than the Mattison site, are there other locations in NW-AR that have**
12 **gas supply?**

13 A: Yes. From the map in the Company’s response to Sierra Club Data Request 1-
14 109, it appears that three gas pipelines serve parts of NW-AR.

15 **VI. Estimates of Control Costs**

16 **Q: For which control costs are SWEPCo’s documentation inadequate?**

17 A: The Company has not adequately explained its estimates of the costs of the
18 combined scrubber and integrated baghouse (in a system that the manufacturer
19 Alstom calls “NID”) and the SCR.

20 **Q: Is it clear what emission limits these pollution-control systems must meet?**

21 A: No. The Company asserts that the dry flue-gas-desulfurization system and low-
22 NO_x burners and overfire air will be needed to meet SO₂ and NO_x limits,
23 respectively, under the BART requirements of the Regional Haze Rule (Hend-
24 ricks Direct at 9). However, as SWEPCo acknowledges (Hendricks Direct at 8),

1 the EPA has not yet finalized the BART requirements that will apply to Flint
2 Creek. EPA partially disapproved the Arkansas State Implementation Plan for
3 regional haze. Specifically, EPA rejected the proposed presumptive emission
4 limits that were the basis for the proposed pollution controls.²³ Hence, the
5 regulatory requirements upon which SWEPCo justifies the economics of the
6 Project are no longer in effect.

7 The Company acknowledges that the “final NO_x and SO₂ emission
8 limits...will be at least as stringent as the [rejected] presumptive limits” (Hend-
9 ricks Direct at 9). Yet SWEPCo has not demonstrated that the Project would cost-
10 effectively comply with more stringent limits. The Company admits that “the
11 prospect that the final EPA-approved Regional Haze SIP could potentially require
12 further NO_x reductions [creates] the potential need for SCR” (Hendricks Direct
13 at 16). Other regulations may also affect SO₂ and NO_x emission limits and
14 hence the capital and operating cost of Flint Creek’s environmental controls.²⁴
15 The Company has not presented the capital and operating costs associated with
16 meeting any specific requirements more stringent than the presumptive BART
17 limits for SO₂ and NO_x.

²³The EPA disapproved the SO₂ and NO_x BART determinations for Flint Creek rejecting Chapter 15 of Arkansas’ Air Pollution Control and Ecology Commission Regulation No. 19, the State’s Regional Haze Rule. The BART determinations for Flint Creek in the Arkansas SIP were based on the presumptive BART limits established in the Rule instead of a five-factor BART analysis. The EPA rejected that approach and insists on a five-factor BART analysis (77 Fed. Reg. 14604, 14651, Mar. 12, 2012).

²⁴Examples of those regulations include rules implementing the 75-ppb National Ambient Air Quality Standard (NAAQS) for ozone set in 2008 but not yet implemented, the still lower ozone NAAQS anticipated in 2013, and the one-hour SO₂ NAAQS, for which EPA is currently developing rules for determining compliance.

1 **Q: What are the implications of this regulatory uncertainty?**

2 A: In the absence of a final BART determination, showing that retrofitting and con-
3 tinuing to operate Flint Creek is in the public interest would require a demon-
4 stration that continued operation would be cost-effective under the plausible
5 range of required controls.²⁵ Other than including an SCR, SWEPCo has not
6 attempted to make that demonstration.

7 **Q: How did the Company estimate the cost of the NID?**

8 A: That is a simple question with a complicated and unsatisfying answer. Company
9 Witness Beam states, “a detailed cost estimate for a DFGD [dry flue-gas desul-
10 furization system] has not been completed for Flint Creek since engineering and
11 design is only in the very early phases”²⁶ (Beam Direct at 19). Specifically, the
12 cost estimate for the Flint Creek NID system

13 was developed from technology evaluations and estimates associated with
14 FGD studies for AEP’s Big Sandy and Rockport Plants and AEP’s years of
15 experience with environmental system construction and startup execution.
16 Competitive bids were solicited for various removal technologies as part of
17 these studies; however, the pricing was based on highly indicative supplier
18 estimates with little to no site specific detail. The selected bid proposal
19 estimates were converted to \$/kW indicative pricing to allow for scaling of
20 pricing associated with Flint Creek’s 528 MW unit size.... (Beam Direct at
21 26–27.)

22 This description of how these cost estimates were derived is troubling
23 enough, as it states that the estimates were derived by making the following
24 assumptions:

²⁵As I demonstrate in Section II, SWEPCo’s claim of cost-effectiveness, even with the control requirements that the EPA rejected, relies on outdated fuel-price forecasts, excessive transmission-related costs, and a constrained set of alternative resources.

²⁶The Company uses DFGD to refer to the NID system, which is a proprietary DFGD with an integral baghouse.

- 1 • the cost per kilowatt for 528-MW Flint Creek would be the same as for the
2 800-MW Big Sandy–2 plant and the two 1,300-MW Rockport units (which
3 would be less expensive, all else equal, due to economies of scale);
- 4 • the cost of the system for Flint Creek, which burns Power River Basin
5 subbituminous coal, would be the same as for the Big Sandy and Rockport
6 units, which burn high-sulfur eastern bituminous coal;
- 7 • “highly indicative supplier estimates with little to no site specific detail”
8 represent unbiased estimates of the actual costs of scrubbers, even at Big
9 Sandy and Rockport.

10 At least Mr. Beam’s testimony suggests that the cost estimate for the NID
11 was based on some sort of estimates (however shaky) for similar systems at
12 other plants (however different). The actual source of the NID cost estimate,
13 however, seems to be even less reliable.

14 The “Flint Creek \$/kW Indicative Pricing Conversion” provided in re-
15 sponse to Sierra Club Data Request 1-30(d), Attachment 1, shows that the Com-
16 pany’s indicative pricing conversion for the NID was not based on the bids for
17 DFGD at Big Sandy and Rockport. Instead it was derived from the \$375/kW
18 actual costs of the 2009 installation of a wet FGD at AEP’s 375-MW Conesville 4,
19 which burns high-sulfur eastern bituminous coal. A wet FGD is an entirely
20 different type of scrubber than the dry FGD included in the NID system.

21 The Company assumed that a NID would cost 80% of a wet FGD, inflated
22 the 2009 costs to year-end 2015, and added a 20% contingency factor. Based on
23 these adjustment factors, SWEPco estimates 2015 end-of-year in-service costs of
24 \$500/kW for installation of a NID at Flint Creek. The Company then apparently
25 applied additional adjustments and added landfill, rail improvements,
26 continuous emission monitoring, and owner’s costs to yield the \$218 million

1 (\$746/kW in 2011 dollars, plus inflation) of Mr. Weaver's Table 6. The Company
2 does not appear to have provided any support for any of its multiple adjustments.

3 This is an enormous extrapolation, between completely different techno-
4 logies at plants burning fuels with different sulfur and heat contents, through
5 many levels of adjustment. This back-of-the-envelope calculation is an entirely
6 unreliable basis for SWEPCo's key cost estimates in this proceeding.

7 **Q: Would either of the methods SWEPCo has described for estimating the cost**
8 **of the NID be sufficient to allow the Commission to find that the proposed**
9 **project is in the public interest?**

10 A: No. The first method started with unreliable and undocumented estimates (pos-
11 sibly for a similar technology) for much larger units burning different fuels,
12 while the second started with a different technology at a somewhat smaller unit,
13 also burning a different fuel. Neither estimation technique seems to be reason-
14 able or reliable enough to support any pre-approval of the project.

15 **Q: What is SWEPCo's estimate of the cost of the SCR system?**

16 A: While it is not part of the cost of the Project, SWEPCo recognizes that installation
17 of an SCR system would likely be a necessary part of the cost of keeping Flint
18 Creek running on coal over the next several years. The Company estimates its
19 50% share of total costs for installation of an SCR system on the 528 MW Flint
20 Creek unit by 2020 at \$72 million nominal, or about \$213/kW in 2011 dollars
21 (Weaver Direct, Table 6 and associated workpapers). The Company's estimate
22 of the variable SCR Operating Costs is \$0.56/MWh; curiously, SWEPCo does not
23 escalate these costs over time. ("Ex SCW-5 WP (Fixed Cost Modeling
24 Parameters).xls," workpaper provided as partial response to Data Request 1-3)
25 Since the variable costs of SCR include periodic replacement of the precious-
26 metal catalyst, consumption of ammonia, and use of power to run the system, I

1 would expect these costs to rise roughly with general inflation, making it more
2 expensive to keep Flint Creek in operation.

3 **Q: How were these costs derived?**

4 A: I have not found any documentation of SWEPCo's derivation of the SCR costs.
5 The resulting cost estimate does not appear to take into account any site-specific
6 factors, such as the layout of the site after the installation of the NID and other
7 environmental retrofits.

8 **Q: Is the SCR cost that SWEPCo estimated likely to meet future BART require-**
9 **ments under the Regional Haze Rule?**

10 A: That would be hard to determine, since we do not know the NO_x emission
11 levels for which SWEPCo's hypothetical SCR system was designed, and the EPA
12 has partially disapproved the Arkansas State Implementation Plan, so the
13 allowed NO_x emissions for Flint Creek under the Regional Haze Rule are not
14 yet known. The cost of the SCR—especially its operating costs—will vary with
15 the stringency of the eventual Arkansas State Implementation Plan.

16 The Company includes the addition of SCR in 2020 for its base case, with a
17 sensitivity analysis in which SCR is required in 2016. SCR is required under the
18 regional-haze program's Best Available Retrofit Technology ("BART") Require-
19 ment, then the 2016 installation date is far more likely. The first regional-haze
20 planning period ends in 2018 (40 CFR 51.308(e)(2)(iii)). EPA made clear in a
21 recent rulemaking (at 17) that "the BART requirements or alternatives to BART
22 must be fully implemented by 2018."²⁷ This likely implementation date is
23 confirmed by the Company (Hendricks Direct at 15).

²⁷The rule, dated May 30 2012 but not yet published in the Federal Register, is entitled "Regional Haze: Revisions to Provisions Governing Alternatives to Source-Specific Best Available

1 Arkansas has chosen to develop source-specific BART determinations for
2 sources like Flint Creek. The EPA has rejected Arkansas’s proposal to set the
3 NO_x BART for Flint Creek at the emission rate attainable using only combustion
4 controls (such as low-NO_x burners and overfire air), stating it “believes that a
5 proper evaluation of the five statutory factors is likely to demonstrate that emis-
6 sion limits lower than the NO_x and SO₂ presumptive emission limits are BART
7 for Flint Creek” (77 Fed. Reg. 14604, 14651 (Mar. 12, 2012)). Such lower-NO_x-
8 emission limits are attainable primarily through post-combustion controls such
9 as SCR, which is likely to be required by 2018, rather than 2020. The earlier the
10 SCR is required, the greater its present-value cost.

11 **Q: How does SWEPCo’s estimate of the cost of the SCR system compare to other**
12 **estimates?**

13 A: It is rather low. An analysis of SCR-process-equipment costs in 2010
14 (Cichanowicz at 6-2) found that the typical capital cost for SCR installed on a
15 coal plant the size of Flint Creek in 2010–2012 would be about \$270/kW in
16 2008 dollars, and that SCR prices had been rising at about \$15/kW each year.²⁸
17 Including civil engineering and other costs, inflation, and the strong upward
18 time trend in SCR costs, this analysis suggests a capital cost on the order of
19 \$300–\$400/kW in 2011 dollars by 2020. An additional \$100/kW would add
20 about \$25 million in SWEPCo investment and about \$25 million to the present
21 value of the costs of the Flint Creek–coal option, depending on the timing of the
22 SCR installation.

Retrofit Technology (BART) Determinations, Limited SIP Disapprovals, and Federal Implementation Plans.”

²⁸Cichanowicz, J. Edward. “Current Capital Cost and Cost-Effectiveness of Power Plant Emissions Control Technologies.” Utility Air Regulatory Group. January 2010.

1 **Q: Does this conclude your testimony?**

2 A: Yes, at this time. At the time that this testimony was prepared, the Company had
3 not responded to several data requests from the parties to this proceeding. Thus,
4 I reserve my right to modify my testimony and to address additional issues in
5 my rebuttal testimony, based on the Company's future responses to data
6 requests.

CERTIFICATE OF SERVICE

I, Jeff Speir, do hereby certify that on the 29th of June, 2012, a true and correct copy of the Direct Testimony and Exhibits of Paul Chernick on Behalf of the Sierra Club was electronically mailed to all parties on the service list for this docket.

Valerie Boyce
APSC General Staff
1000 Center Street
Little Rock, AR 72204
Valerie_boyce@psc.state.ar.us

Cindy Uhrynowycz
APSC General Staff
1000 Center Street
Little Rock, AR 72204
cuhrynowycz@psc.state.ar.us

Emon O. Mahony
Assistant Attorney General
323 Center St., Ste. 200
Little Rock, AR 72201
emon.mahony@arkansasag.gov

M. Shawn McMurray
Senior Assistant Attorney General
323 Center St., Ste. 200
Little Rock, AR 72201
shawn.mcmurray@arkansasag.gov

Forrest Kessinger
1 Cooperative Way
Little Rock, AR 72218
fkessinger@aecc.com

Stephen Williams
Arkansas Electric Cooperative Corp.
PO Box Little Rock, AR 72219
steve.williams@aecc.com

Dave Slaton
APSC Commissioners' Staff
1000 Center Street
Little Rock, AR 72204
Dslaton@psc.state.ar.us

Stephan Cuffman
Southwest Electric Power Company
425 West Capitol, Suite 3801
Little Rock, AR 72201
Cuffman@gill-law.com

Hank Steele
Southwest Electric Power Company
1201 Elm Street, Suite 800
Dallas, TX 75270
hcsteele@aep.com

/s/ Jeff Speir

Jeff Speir
Sierra Club
85 Second Street, Second floor
San Francisco, CA 94105
(415) 977-5595
jeff.speir@sierraclub.org